



**SCLA  
FUEL FARM FIRE SUPPRESSION SYSTEM ANNUAL CERTIFICATION  
PROJECT #ES12-042**

**JUNE 26, 2012**

**ADDENDUM #1**

The attached constitutes additional information and serves to clarify issues (considered to be part of the Southern California Logistics Airport Authority “**SCLA Fuel Farm Fire Suppression System Annual Certificate, Project ES12-042).**”

Should you have any questions, please feel free to contact Elizabeth Salcido, Purchasing Technician at (760) 243-6371, Fax (760) 269-0045, or email: [esalcido@ci.victorville.ca.us](mailto:esalcido@ci.victorville.ca.us).

**GENERAL QUESTIONS/ANSWERS:**

1.    **Q.    Are contractors to test the UVIRS flame detectors on the fuel tanks?**  
      A.    *Yes.*
  
2.    **Q.    Are contractors to check the foam chamber glass for vapors?**  
      A.    *Yes.*
  
3.    **Q.    On the control panel, is testing to include the fire alarm as well as foam?**  
      A.    *Yes.*
  
4.    **Q.    Are contractors to test the shut-offs at the fuel tanks as well as the electrical control panel building?**  
      A.    *Yes.*
  
5.    **Q.    Does the one pull station by the fuel tanks control everything?**  
      A.    *There are two pull stations at the fuel transfer area. The individual pull stations at the control panel building control individual fire alarm notification and fuel tank foam activation.*
  
6.    **Q.    Are contractors to test both the pull station and the controls by both the fuel station as well as the control panel building?**  
      A.    *Yes.*
  
7.    **Q.    Are contractors to flow water out of cannons and test?**  
      A.    *Yes.*

8. Q. **In order to test the water flow, will contractors be required to have a vactor truck or are contractors allowed to let the water drain on the ground?**  
A. *Contractors are allowed to let water flow on the ground.*
9. Q. **Are plans for suppression system available?**  
A. *Yes, copies of plans may be obtained from the Fire Department located at City of Victorville City Hall.*

### **REVISIONS**

**ATTACHMENT A –SCOPE OF WORK** – Revised to correct Chapter 19 title 5 to read Title 19.

### **ATTACHMENTS**

Attachment A, Fuel Farm Fire Suppression System Annual Certification  
Pre-Bid Meeting Sign-In Sheet

\*\*\*\*\*

Please confirm receipt of this Addendum #1, ES12-042, by either faxing the acknowledgment to the City of Victorville, Purchasing Division at (760) 269-0045, or by attaching the signed acknowledgment to your bid proposal. **Failure to acknowledge receipt of this addendum may result in the disqualification of your proposal.** The undersigned acknowledges receipt of ADDENDUM #1:

Name of Bidder \_\_\_\_\_

Address \_\_\_\_\_

Telephone No. \_\_\_\_\_ Fax No: \_\_\_\_\_

Signature: \_\_\_\_\_

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date

**ADDENDUM #1  
ATTACHMENT A  
SCOPE OF WORK  
PROJECT ES12-042**

**Fuel Farm Fire Suppression System Annual Certification**

Perform annual certification of fire sprinkler system and foam system located at SCLA fuel farm, 18373 Gateway, Victorville CA 92394, in accordance with the NFPA 72, NFPA 25, and Title 19 of the California Code.

Contractor/sub contractor must have C-10 and C-16 licenses.

Perform necessary repairs as needed.

Include hourly rate and parts mark-up.

A mandatory bid walk will be required.

# PRE-BID MEETING SIGN IN SHEET

Tuesday, June 26, 2012  
10:00 a.m.

PROJECT NAME: Fuel Farm Fire Suppression,

PROJECT #: Project ES12-042

COMPANY NAME & REPRESENTATIVE	ADDRESS	PHONE #	FAX #	E-MAIL
City of Victorville – Elizabeth Salcido Purchasing Technician/Contract Administrator.	14343 Civic Dr. Victorville, CA 92392	(760) 243-6371	(760) 269-0045	<a href="mailto:esalcido@ci.victorville.ca.us">esalcido@ci.victorville.ca.us</a>
City of Victorville – Celeste Calderon Management Specialist /Contract Administrator	14343 Civic Dr. Victorville, CA 92392	(760) 955-5082	760) 269-0045	<a href="mailto:ccalderon@ci.victorville.ca.us">ccalderon@ci.victorville.ca.us</a>
SCLAA – Richard Falzone Airport Field Supervisor	18374 Phantom Drive Victorville, CA 92394	(760) 243-1945	(760) 243-1929	<a href="mailto:rfalzone@ci.victorville.ca.us">rfalzone@ci.victorville.ca.us</a>
SCLAA – Heather Kurowski Management Technician	14343 Civic Dr. Victorville, CA 92392	(760)-243-1905	(760) 243-1929	hkurowski@ci.victorville.ca.us
Bruce Deushane Jam Corporation	1930 S. Myrtle Ave. Monrovia, CA 91016	(626) 256-4400	(626) 256-4401	Bruce.deushane@jamfire.com
Steve Parks DCS Testing & Equipment, Inc.	4637 W. 159 <sup>th</sup> St. Lawndale, CA 90260	(310) 542-3004	(310) 542-7183	sparks@dcstesting.com
Kevin Clark Scorpion Fire Protection	9624 Joshua St. Apple Valley, CA 92308	(760) 885-6691	(760) 240-4803	<a href="mailto:Fireprokdc1@verizon.net">Fireprokdc1@verizon.net</a>
Joe Zuccaro SBC Co. Fire Department – VV	14343 Civic Drive Victorville, CA 92392	(760) 955-5234	(760) 269-0020	jzuccaro@ci.victorville.ca.us