



**HANGER 676, FIRE SUPPRESSION REPAIRS  
PROJECT # ES12-006  
November 17, 2011**

**ADDENDUM #2**

The attached constitutes additional information and serves to clarify issues (considered to be part of the City of Victorville "Hanger 676, Fire Suppression Repairs, Project ES12-006").

Should you have any questions, please feel free to contact Elizabeth Salcido, Purchasing Technician at (760) 243-6371, Fax (760) 269-0045, or email: [esalcido@ci.victorville.ca.us](mailto:esalcido@ci.victorville.ca.us).

**GENERAL QUESTIONS/ANSWERS:**

1. **Q. Will the awarded contractor have to submit plans in advance and await Fire Department approval prior to performance of work?**  
A. *No. Contractor may submit project product submittals for approval and then provide the as builts after the work is completed.*
2. **Q. Are contractors to add five (5) inspector test valves?**  
A. *Yes.*
3. **Q. How long will it take to obtain Fire Department approval of product submittals?**  
A. *If contractors arrange submittals with the Fire Department Supervisor ahead of time, submittals may be approved the same day.*
4. **Q. Since it has been determined by all parties that Scope of Work, Item 3B, is neither the most cost efficient or technically feasible option; will SCLAA be removing this from option from the bid proposal submittal?**  
A. *Yes. Option 3B is hereby removed from the solicitation. A revised Bid Form is attached to this Addendum removing Option 3B from the solicitation. Please ensure this revised form is returned as your bid response.*

**ATTACHMENTS**

Pre-Bid Meeting Sign In Sheet  
Revised Bid Form, Page 4 of the solicitation

\*\*\*\*\*

Please confirm receipt of this Addendum #2, ES12-006 by either faxing the acknowledgment to the City of Victorville, Purchasing Division at (760) 269-0045, or by attaching the signed acknowledgment to your bid proposal. **Failure to acknowledge receipt of this addendum may result in the disqualification of your proposal.** The undersigned acknowledges receipt of ADDENDUM #2:

Name of Bidder \_\_\_\_\_

Address \_\_\_\_\_

Telephone No. \_\_\_\_\_ Fax No: \_\_\_\_\_

Signature: \_\_\_\_\_

\_\_\_\_\_  
Title

\_\_\_\_\_  
Date

# PRE-BID MEETING SIGN IN SHEET

Thursday, November 17, 2011  
10:00 a.m.

PROJECT NAME: **Hanger 676 Fire Suppression System Repairs**

PROJECT #: **ES12-006**

| COMPANY NAME & REPRESENTATIVE  | ADDRESS   | PHONE #        | FAX #          | E-MAIL   |
|--|---|----------------|----------------|--|
| City of Victorville – Elizabeth Salcido<br>Purchasing Technician/Contract Administrator. | 14343 Civic Dr.<br>Victorville, CA 92392                      | (760) 243-6371 | (760) 269-0045 | <a href="mailto:esalcido@ci.victorville.ca.us">esalcido@ci.victorville.ca.us</a>     |
| City of Victorville – Bruce Miller<br>Buyer /Contract Administrator                      | 14343 Civic Dr.<br>Victorville, CA 92392                      | (760) 955-5085 | 760) 269-0045  | <a href="mailto:bmiller@ci.victorville.ca.us">bmiller@ci.victorville.ca.us</a>       |
| SCLAA – Richard Falzone<br>Project Manager   | 18374 Phantom Drive<br>Victorville, CA 92394                  | (760) 243-1945 | (760) 243-1929 | <a href="mailto:rfalzone@ci.victorville.ca.us">rfalzone@ci.victorville.ca.us</a>     |
| SCLAA – Dan Raschke<br>Lead Worker   | 18374 Phantom Drive<br>Victorville, CA 92394                  | (760) 243-1945 | (760) 243-1929 | <a href="mailto:draschke@ci.victorville.ca.us">draschke@ci.victorville.ca.us</a>     |
| San Bernardino Co. Fire - Joe Zuccaro,<br>Fire Prevention Supervisor                     | 14343 Civic Dr.<br>Victorville, CA 92392                      | (760)-955-5234 |                | <a href="mailto:jzuccaro@ci.victorville.ca.us">jzuccaro@ci.victorville.ca.us</a>     |
| DCS Testing & Equipment, Inc.<br>Steve Ward  | 4637 W. 159 <sup>th</sup> St.<br>Lawndale, CA 90260           | (310)-542-3004 | (310)-542-7183 | <a href="mailto:sward@dstesting.com">sward@dstesting.com</a>                         |
| DCS Testing & Equipment, Inc.<br>Daniel Clarke   | 4637 W. 159 <sup>th</sup> St.<br>Lawndale, CA 90260           | (310)-542-3004 | (310)-542-7183 | <a href="mailto:dclarke@dcstesting.com">dclarke@dcstesting.com</a>                   |
| Champion Fire Systems, Inc.<br>Jim Shehan, President                                     | 12170 Santa Margarita Court,<br>Rancho Cucamonga, CA<br>91730 | (909) 483-9789 | (909) 484-9670 | <a href="mailto:JShehan@ChampionFireSystems.com">JShehan@ChampionFireSystems.com</a> |
|  |   |                |                |  |
|  |   |                |                |  |

**PROJECT ES12-006  
ADDENDUM #2  
NOVEMBER 17, 2011**

**BID PROPOSAL FORM:**

The undersigned declares that the specifications and contract documents have been carefully examined; and being familiar with all conditions surrounding the work, including the availability of materials and labor, the undersigned hereby proposes to furnish all labor, materials, tools, equipment, and incidentals to complete all work. All of the aforementioned shall be done in accordance with said specifications and contract documents for the price set forth in the following schedule.

Note: All prices to include all appropriate taxes and any/all discounts.

**THIS PROJECT IS SUBJECT TO STATE PREVAILING WAGE RATE**

**Option A**

| ITEM | DESCRIPTION   | COST |
|------|---|------|
| 1.   | <b>Replace Open Head Sprinklers with Closed Head Sprinklers 700 heads to be changed. Install 5 new 6" alarm valves and flow switches as needed and re-program panel. Also provide as built for Fire Dept.</b> | \$   |

Grand Total in Words: \_\_\_\_\_

Payment Terms: \_\_\_\_\_

FOB: Victorville, CA (Shipping Prepaid)

Bidder: \_\_\_\_\_

Address: \_\_\_\_\_  
Mailing Address City State Zip Code

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_ E-mail: \_\_\_\_\_

\_\_\_\_\_  
Signature Date

\_\_\_\_\_  
Name printed Title