



# San Bernardino County Fire Department

## Victorville Division

### Plan Submittal Requirements

14343 Civic Drive  
PO Box 5001  
Victorville, CA 92393-5001  
(760) 955-5227  
Fax (760) 269-0020  
www.victorvilleca.gov

## Kitchen Hood Suppression System

### Three complete sets of plans to include:

- Fully dimensioned plan
- Assessor's Parcel Number, street address, building number and/or suite number (if applicable)
- Project and/or building name
- Name, address, phone number and license number of the fire protection contractor ("C16" license classification)
- Equipment symbol legend
- Equipment part numbers
- Verify system is UL 300 listed
- Plan view of room and all equipment
- System model and permissible number of flow points
- Description and measurements of appliances to be protected
- Type of fuel or power shut-off device
- Number of nozzels and aggregate flow rate, total flow points and nozzle types identified
- Show location of pull station in path of egress and height from floor

### Additional requirements:

- Manufacturers design manual or pages related to submitted installation

**All plans and documents submitted shall be drawn to scale. These are the minimum general requirements for plan check submittal. Additional documents may be required upon review.**