

## PROCEDURES

### CAUTION TAPE

---

#### 8.0 PURPOSE

The purpose of this section is to establish the minimum requirements for the installation of caution tape with all newly installed or replaced gas mains and services.

#### 8.1 SCOPE

A. Installation of caution tape.

#### 8.2 CAUTION TAPE

Caution tape shall be:

- A. Installed 12” to 18” directly above the pipe.
- B. Yellow in color.
- C. Caution tape shall state **CAUTION - BURIED GAS PIPELINE.**
- D. Installer shall take precautions to insure that the caution tape is protected and remains above the gas piping during the backfill process.
- E. When installing main or service in sleeve or casing in an open trench, place the caution tape 12” to 18” above the sleeve or casing.
- F. Plastic material.