



City of Victorville

Development Department

Planning ♦ Building ♦ Code Enforcement ♦ Business License

14343 Civic Drive
PO Box 5001
Victorville, CA 92393-5001
(760) 955-5100
Fax (760) 269-0073
planreview@victorvilleca.gov

Conventional Framing Span Tables For Douglas Fir-Larch (North) No. 2

2016 CBC, CRC

Nominal Member Size	On Center Spacing	Roof Rafters Maximum Allowable Span
2 x 4 Only on lattice patios	12"	9'-10"
	16"	8'-6"
	24"	7'-9"
2 x 6	12"	14'-4"
	16"	12'-5"
	24"	11'-4"
2 x 8	12"	18'-2"
	16"	15'-9"
	24"	14'-4"
2 x 10	12"	20'-0"
	16"	19'-3"
	24"	17'-7"
2 x 12	12"	20'-0"
	16"	20'-0"
	24"	20'-0"
All rafter material shall have a minimum structural grade of #2		

HEADER SIZE AND SPAN

Rafter Span	Post Spacing	Header Size
Maximum Rafter Span 20' See chart above for span and spacing of rafters	4'	4 x 4
	6'	4 x 6
	8'	4 x 8
	10'	4 x 10
	12'	4 x 12
All header material shall have a minimum structural grade of #1		

*This sheet shall be for reference only and shall not be a substitute for accurate drawings prepared for each individual construction project.