



# CITY OF VICTORVILLE

## FIRE PREVENTION DIVISION

14345 Civic Center Drive  
Victorville, CA 92392  
(760) 955-5233

Standard Number

**S-2**

Revision Date:  
11-5-25

## FIRE PREVENTION STANDARD S-2 AUTO WRECKING AND STORAGE YARDS

### AUTHORITY

California Fire Code Sections 102.9, 103, and section 104.1.1 as amended in section 8.08.04<sup>(5)</sup> of the City of Victorville Municipal Code provides that the fire code official of the City of Victorville shall have the authority to adopt policies, procedures, rules, and regulations in order to clarify the application of the Fire Code and to specify requirements not specifically provided for by the Fire Code. This standard may be modified with the approval of the Fire Code Official.

### PURPOSE

The purpose of this standard is to provide guidance for the safe operation of auto wrecking and storage yards, and to minimize the risk of fires and thus provide improved protection against injury, life loss, and property damage.

### SCOPE

This standard shall apply to the use and operation of automotive wrecking and storage yards.

### DISCLAIMER

*These standards may change without notice. Whenever applicable statutes, regulations, and standards are updated and adopted, the latest shall apply. Please contact the Victorville Fire Prevention Division at (760) 955-5227 to determine if these standards have changed. These requirements do not exempt any individual from complying with other applicable state, county, or city codes and standards.*

### GENERAL

Automobile wrecking yards shall be in accordance with this standard.

### FIRE APPARATUS ACCESS ROADS

- 1) Fire apparatus access roads shall be provided in accordance with the current California Fire Code, Victorville Municipal Code, and City of Victorville Fire Prevention Standards A1, A2, A3.
- 2) Fire apparatus access roads shall not be obstructed by any vehicles or storage at any time.

### FIRE HYDRANTS

- 1) Required fire flow for auto wrecking and storage yards is 1500 GPM at 20 PSI.
- 2) Fire hydrants shall be spaced at three hundred (300) feet apart, with no part of the building more than one hundred fifty (150) feet from any hydrant. Additional on-site hydrants may be
- 3) required by the Fire Code Official.



# CITY OF VICTORVILLE

## FIRE PREVENTION DIVISION

14345 Civic Center Drive  
Victorville, CA 92392  
(760) 955-5233

Standard Number

**S-2**

Revision Date:  
11-5-25

## FIRE PREVENTION STANDARD AUTO WRECKING AND STORAGE YARDS

### HAZARDOUS MATERIALS

- 1) Contact the Hazardous Material Division of San Bernardino County Fire Department Office of Fire Marshal (CUPA) and submit a Business Emergency/Contingency Plan.
- 2) Obtain a valid EPA ID number.
- 3) Motor vehicle fluids shall be drained from salvage vehicles when such fluids are leaking. Flammable and combustible liquids shall be stored in accordance current California Fire Code, Victorville Municipal Code, and all applicable Hazardous Materials and Hazardous Waste Generator laws and regulations.
- 4) Lead-acid Batteries shall be stored in a covered storage area on an impervious surface with secondary containment, or in a non-leaking container with a lid, and properly managed.
- 5) All storage containers shall be properly labeled.
- 6) Safety Data Sheets shall be current and available for viewing.
- 7) Compressed gas cylinders shall be secured to prevent falling due to contact, vibration or seismic activity per the current California Fire Code and Victorville Municipal Code.
- 8) Stored vehicles shall have a barrier between the fluid leaks and the ground.
- 9) Provide secondary containment for all hazardous liquids.
- 10) A minimum of one 4A40BC fire extinguisher shall be readily available and the individual employees shall be trained in the proper use of the fire extinguisher.

### HOT WORK

- 1) Welding and cutting shall not be conducted in areas where flammable liquids or combustibles are in close proximity. A welding permit is required.
- 2) Appropriate shielding shall be provided, along with a fire watch during hot work operations.
- 3) Combustible material shall be cleared a minimum of 35 feet radius from hot work area.
- 4) A least one portable fire extinguisher with a minimum rating of 4A40BC shall be readily accessible within 30 feet of the location where hot work is performed.
- 5) All containers, cylinders, and tanks shall be secured and stored per the current California Fire Code and Victorville Municipal Code.

### HOUSEKEEPING

- 1) Combustible debris and vegetation shall be removed from the location and placed in approved containers.



# CITY OF VICTORVILLE

## FIRE PREVENTION DIVISION

14345 Civic Center Drive  
Victorville, CA 92392  
(760) 955-5233

## FIRE PREVENTION STANDARD AUTO WRECKING AND STORAGE YARDS

Standard Number

**S-2**

Revision Date:  
11-5-25

- 2) Oily rags shall be kept in an approved metal container with a self-closing metal lid.

### TIRE STORAGE

- 1) Tire storage shall be in accordance with California Fire Code, Chapter 34, and Victorville Municipal Code. Note: when deemed a hazard, the Fire Code Official may require smaller pile dimensions.
- 2) Individual tire pile storage shall not exceed 5,000 square feet of continuous area. Pile width shall not exceed 50 feet. Piles shall not exceed 50,000 cubic feet in volume or 10 feet in height.
- 3) Separation between tire piles and between other stored products shall be a minimum of 40 feet.
- 4) Tire pile distance from property lines and buildings shall be 50 feet.
- 5) Tire storage piles with less than 500 tires shall be permitted to be located 10 feet from property lines and buildings. Piles shall not be higher than 6 feet within 20 feet from building(s) and property line(s).
- 6) Interior rack storage of tires shall comply with the current California Fire Code and Victorville Municipal Code.