



**NOTES:**

- A. ALL SERVICE LINES SHALL BE MINIMUM DEPTH OF 24" BELOW FINISHED GRADE.
- B. ALL SERVICE MATERIAL SHALL BE NEW; REFER TO STD. DWG. W-10 FOR PLACEMENT OF ANGLE STOP AND METER BOX.
- C. ITEMS 9 AND 10 TO BE INSTALLED BY CONTRACTOR AFTER THE METER HAS BEEN SET, UNLESS SERVICE INSTALLATION WAS PAID FOR.
- D. IF REQUIRED, A DEPARTMENT OF PUBLIC HEALTH APPROVED, OWNER INSTALLED, REDUCED PRESSURE BACKFLOW PREVENTION DEVICE TO BE TESTED PRIOR TO SERVICE ACTIVATION IN ACCORDANCE WITH W-39.

ITEM	DESCRIPTION	APPROVED MATERIAL LIST NUMBER
1	"MAIN SIZE" x 1" SERVICE SADDLE	7-B
2	1" CORP. STOP (MIP x COMPRESSION)	2-C
3	1" SERVICE LATERAL (LENGTH VARIES)	1-D
4	NOT USED	6-D
5	1" x 1" ANGLE METER STOP	2-E
6	3/4" x 1" METER BUSHING (NOT REQUIRED ON 1" METERS)	13-B
7	METER (FURNISHED AND INSTALLED BY VWD)	13-C
8	NOT USED	2-H
9	3/4" OR 1" BALL VALVE PER RESPECTIVE METER SIZE	2-I
10	METER BOX SIZE (13"W x 24"L x 12"D)	9-D
11	3/4" OR 1" SERVICE FITTING (MIP X C110) PER RESPECTIVE METER SIZE	6-D
12	3/4" OR 1" COPPER TUBING PER RESPECTIVE METER SIZE	1-D

**CITY OF VICTORVILLE - ENGINEERING DEPARTMENT**

REV.	DATE	BY	TYPICAL SERVICE INSTALLATION FOR 3/4" AND 1" METERS	W-01
4	9/14/16	STAFF		
3	4/5/16	STAFF		
2	3/12/15	STAFF	BRIAN W. GENGLER, CITY ENGINEER	SHEET 1 OF 1